BLACK FOREST FIRE RESCUE

Division of Fire Marshal

11445 Teachout Road | Colorado Springs, CO 80908

CWRC ROOFING APPLICATION & SELF-INSPECTION

WUI Class 1 and Class 2 | Roofing replacement or repair

Complete page 1 for application review. Complete and sign page 2 after installation.

CONTRACTOR NAME

DATE

COMPANY REPRESENTATIVE

BUSINESS NAME (if applicable)

COMPANY ADDRESS

PHONE

EMAIL

PROPERTY ADDRESS

PPRBD ROOFING PERMIT NUMBER

OWNER NAME

SCOPE OF WORK

☐ Repair ☐ Replacement ☐ Residential ☐ Commercial

☐ Structural modifications are included to meet Class A roof assembly requirements.

TOTAL ROOF SURFACE AREA (sq. ft.)

AREA TO BE REPLACED / REPAIRED (sq. ft.)

ROOFING MATERIAL / MANUFACTURER / MODEL

CAP SHEET / UNDERLAYMENT DESCRIPTION

VALLEY FLASHING GAGE / WIDTH

DRIP EDGE MATERIAL (leading edge extends into gutter)

BLACK FOREST FIRE RESCUE

Division of Fire Marshal

11445 Teachout Road | Colorado Springs, CO 80908

CWRC ROOFING APPLICATION & SELF-INSPECTION

Complete this page after the roofing work is installed

PROPERTY ADDRESS

PPRBD PERMIT NUMBER

For applicable Class 1 or Class 2 roof work affecting 25% or more of the roof surface, use the following checks. YES means the completed work complies; NO means correction or review is needed; N/A means outside the approved scope.

ROOFING SELF-INSPECTION

	YES	NO	N/A
The installed roof covering / assembly is Class A. Roof-profile openings are protected against flame and ember intrusion. **CWRC 403.2 and 403.2.1.**	○	○	○
Roof valleys have the required corrosion-resistant metal flashing and underlayment. **CWRC 403.2.2.**	○	○	○
Gutters and downspouts included in the work are noncombustible. **CWRC 403.3.**	○	○	○
Roof vents installed or replaced with this work meet the applicable ember-resistance requirements. **CWRC 403.4.**	○	○	○

I inspected the completed roofing work and certify that these responses describe the installed condition. I have explained incomplete items below. BFFR inspection and approval remain required when applicable.

CONTRACTOR / OWNER SIGNATURE (type name or sign)

DATE

INCOMPLETE ITEMS / EXPLANATION OF N/A / REQUEST FOR BFFR REVIEW

BFFR USE ONLY

○ CWRC not applicable ○ Roofing accepted ○ Corrections required

BFFR reviewer / signature / date

Reviewer conditions

Only BFFR may complete this section. Self-inspection alone does not release a permit hold.

Save this PDF and submit through the BFFR website. Contact BFFR for the current submission route.

BFFR website / submission information