BLACK FOREST FIRE RESCUE

Division of Fire Marshal

11445 Teachout Road | Colorado Springs, CO 80908

SCHOOL / CLASSROOM FIRE INSPECTION

School inspection checklist and classroom guidance

SCHOOL / FACILITY

INSPECTION DATE

ADDRESS

PRINCIPAL / FACILITY CONTACT

PHONE / EMAIL

INSPECTOR / PERSON COMPLETING FORM

BUILDING / ROOM(S) INCLUDED

YES = compliant at the time checked; NO = correction needed; N/A = not applicable. Explain findings on page 2. This checklist does not replace required inspections.

ARTWORK / TEACHING MATERIALS

	YES	NO	N/A
Classroom artwork and teaching materials do not exceed 50% of the specific wall area to which they are attached. **IFC 807.5.2.3.**	○	○	○
Corridor artwork and teaching materials do not exceed 20% of corridor wall area. **IFC 807.5.2.2.**	○	○	○
Decorations do not obscure exits, obstruct fire equipment, interfere with door closing or extend through door frames.	○	○	○

Record the wall-area calculation below. Identify any excluded windows, doors, boards, televisions or fixed furnishings. BFFR must confirm the accepted gross- or net-area method for this school.

ROOM / WALL IDENTIFIER

WALL AREA USED (sq. ft.)

ARTWORK AREA (sq. ft.)

CALCULATED COVERAGE (%)

BFFR-ACCEPTED CALCULATION METHOD

DECORATION FINDINGS / CALCULATION NOTES

BLACK FOREST FIRE RESCUE

Division of Fire Marshal

11445 Teachout Road | Colorado Springs, CO 80908

SCHOOL / CLASSROOM FIRE INSPECTION

Classroom safety checks and correction record

SCHOOL / FACILITY

ROOM(S)

CLASSROOM COMMON FIRE-SAFETY ITEMS

	YES	NO	N/A
Required exit doors open readily from the inside and are not obstructed or improperly locked.	○	○	○
Exit aisles, corridors and stairs retain their required clear width and are free of storage.	○	○	○
No prohibited combustible storage is present under stairs, above ceilings, or in equipment / mechanical rooms.	○	○	○
Storage maintains required separation from sprinklers and ceilings (normally 18 inches below sprinkler deflectors or 24 inches below an unsprinklered ceiling, subject to applicable exceptions).	○	○	○
Listed power strips plug directly into an approved wall receptacle; power strips are not connected to other power strips.	○	○	○
Extension cords are not a substitute for permanent wiring and do not pass through walls, doors or ceilings.	○	○	○
Electrical panels have the required unobstructed working space and no blocked access.	○	○	○
Electrical boxes have covers; damaged wiring and unapproved multi-plug adapters are not present.	○	○	○
Fire-resistive walls / ceilings are intact; openings or penetrations are properly protected.	○	○	○
Fire doors close and latch as designed and are not wedged or improperly held open.	○	○	○

CORRECTIONS / RESPONSIBLE PERSON / DUE DATE

INSPECTOR / REVIEWER

SCHOOL REPRESENTATIVE

FOLLOW-UP DATE

Save this PDF and submit through the BFFR website. Contact BFFR for the current submission route.

BFFR website / submission information